

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 19/02/25

It is certified that an inspection team headed by Kalpana Poya S/E
 (Name of Officers with designation) from E.E.P.H.E. Division - Durg
 (Name of Department/ Office) inspected the **KRISHNA PUBLIC SCHOOL,**
KUTELABHATA, BHILAI-DURG, DISTT.- DURG, CHHATTISGARH on 19/02/2025
 (date of inspection) and found that the **KRISHNA PUBLIC SCHOOL, KUTELABHATA** has
 safe drinking water facilities for the students and members of staff of the institution and is
 maintaining the hygienic sanitation condition in the school building & the campus as per
 norms prescribed by the Central/State/ U.T. Govt.

The above is valid for a period of 1 Year

Office of the Executive Engineer
 Public Health Engg. Division
 Durg (Chhattisgarh)

Signature with Seal: Kalpana Poya

Name : Kalpana Poya

Designation : Sub Engineer

Name & Address of the Office / Department :

To,

The Principal
 Krishna Public School
 Kutelabhata, Bilai-Durg, Distt.- Durg (C.G.)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

MANAGER
 KRISHNA PUBLIC SCHOOL
 KUTELABHATA, BHILAI-DURG (C.G.)

PRINCIPAL
 KRISHNA PUBLIC SCHOOL
 KUTELABHATA, BHILAI-DURG (C.G.)

District Water Testing Laboratory

Public Health Engineering Department, Division-Durg (C.G.)

Email – eedurg-phe-cg@nic.in, Phone No. - 0788 - 2323633

Test Report - Chemical**ULR – TC75022500000059F**

Issue No. - DRG/103/ Date-31.01.25		Sampled by :- अनुपम पाण्डेय कृष्णा पब्लिक स्कूल कुटेलाभाटा दुर्ग (छ.ग.)	
Sample Code :-	01/25/98	Sampled On :-	29/01/2025
Sample Name :-	Drinking Water	Quantity of Sample :-	1 Ltr/Sample
Sender's letter No. -	-	Sender's Letter Date :-	29/01/2025
Sample Condition :-	Good	Sample Received On :-	29/01/2025
Test Started on:-	29/01/2025	Test Completed On :-	30/01/2025

Sample Details

S.No.	Block/District	Sample I.D.	Panchayat/Village	Location & Source Discription
01	दुर्ग	883	कुटेलाभाटा	कुटेलाभाटा, थाना-जेवरा सिरसा आई.आई.टी के पास (आर. ओ. का पानी)

Details of parameters, their test methods, units and specifications as per IS:3025 /APHA

S.No	Characteristics	Unit of Measurement	Test method IS 3025 / APHA 24th edition		Acceptable Limit	Permissible Limit in the absence of alternate source	Result of			
			Method	Part No.			883	-	-	-
1	Turbidity	N.T.U.	IS:3025	10	1	5	0.6	-	-	-
2	Colour	Hazen	APHA	2120- B	5	15	3	-	-	-
3	Odour	IS:3025	5	Agreeable	Agreeable	Agreeable	-	-	-
4	Taste	IS:3025	8	Agreeable	Agreeable	-	-	-	-
5	pH value @25°C	IS:3025	11	6.5-8.5	No Relaxation	6.75	-	-	-
6	Total Alkalinity as CaCO ₃	mg/l	IS:3025	23	200	600	29.16	-	-	-
7	Spe. Conductivity @25°C	µmho/cm	IS:3025	14	-	-	286	-	-	-
8	Total Dissolved Solids At 180°C ± 2°C	mg/l	IS:3025	16	500	2000	160	-	-	-
9	Chloride as Cl ⁻	mg/l	IS:3025	32	250	1000	26.86	-	-	-
10	Total Hardness as CaCO ₃	mg/l	IS:3025	21	200	600	87.03	-	-	-

District Water Testing Laboratory

Public Health Engineering Department, Division-Durg (C.G.)

E-mail – eedurg-phe-cg@nic.in, Phone No. - 0788 - 2323633

Test Report - Chemical**ULR – TC75022500000059F****Details of parameters, their test methods, units and specifications as per IS:3025 /APHA**

S.No	Characteristics	Unit of Measurement	Test method IS 3025 / APHA 24th edition		Acceptable Limit	Permissible Limit in the absence of alternate source	Result of			
			Method	Part No.			883	-	-	-
11	Calcium (As Ca ²⁺)	mg/l	IS:3025	40	75	200	18.63	-	-	-
12	Magnesium (As Mg ²⁺)	mg/l	APHA	3500 - Mg- B	30	100	9.83	-	-	-
13	Nitrates as NO ₃ ⁻ (Screening Method)	mg/l	APHA	4500-NO ₃ - B	45	No Relaxation	1.3	-	-	-
14	Iron as Fe ²⁺	mg/l	APHA	3500-Fe-B	1.0	No Relaxation	0.14	-	-	-
15	Manganese (As Mn ⁺)	mg/l	APHA	3500-Mn-B	0.1	0.3	0.0	-	-	-
16	Sulphates as SO ₄ ²⁻	mg/l	IS:3025	24	200	400	14.41	-	-	-
17	Fluorides as F ⁻	mg/l	APHA	4500-F-C	1.0	1.5	0.04	-	-	-

Terms & Condition :-

1. The report should not be produced partly or full without approval of signatory authority of legal purpose.
2. The results refer only to tested samples and parameters.
3. Samples will be stored for a period of 10 days from date of issue of report.
4. Results apply to the sample as received.
5. Sampling not done by Laboratory's Staff.
6. The Laboratory does not give interpretation on test result passed/failed.


(Bisahu Ram Sahu)**END OF THE REPORT**

-----Page - 02 of 02-----



MANAGER
KRISHNA PUBLIC SCHOOL
KUTELABHATA, BHILAI-DURG (C.G.)



PRINCIPAL
KRISHNA PUBLIC SCHOOL
KUTELABHATA, BHILAI-DURG (C.G.)

District Water Testing Laboratory

Public Health Engineering Department, Division-Durg (C.G.)

E-mail – eedurg-phe-cg@nic.in, Phone No. - 0788 - 2323633

Test Report - Bacteria

Issue No. - DRG/103/ Date- 31.01.25		Sampled by:- अनुपम पाण्डेय कृष्णा पब्लिक स्कूल कुटेलाभाटा दुर्ग (छ.ग.)	
Sample Id Code :-	01/25/98	Sampled On :-	29-01-2025
Sample Name :-	Drinking Water	Quantity of Sample :-	1Ltr /Sample
Sender's letter No. -	-	Sender's Letter Date :-	29-01-2025
Sample Condition :-	Good	Sample Received On :-	29-01-2025
Test Started on:-	29-01-2025	Test Completed On :-	30-01-2025

Sample Details

S.No.	Block/District	Sample I.D.	Village	Location & Source Discription
01	दुर्ग	883	कुटेलाभाटा	कुटेलाभाटा, थाना-जेवरा सिरसा आई.आई.टी के पास (आर. ओ. का पानी)

Details of parameters, their test methods, units and specifications as per IS:3025 /APHA

S.No.	Characteristics	Unit of Measurement	Test method IS 3025 / APHA 24th edition		Acceptable Limit	Permissible Limit in the absence of alternate source	Result of				
			Method	Part No.			883	-	-	-	-
1	Residual chlorine	mg/l	IS:3025	26	0.2	1	-	-	-	-	-
2	E.coli	CFU/100	APHA	9222 B	Nil	Nil	00	-	-	-	-
3	Arsenic as As	mg/l	IS:3025	37	0.01	No Relaxation	-	-	-	-	-

Terms &Condition :-

1. The report should not be produced partly or full without approval of signatory authority of legal purpose.
2. The results refer only to tested samples and parameters.
3. Samples will be stored for a period of 10 days from date of issue of report.
4. Results apply to the sample as received.
5. Sampling not done by Laboratory's Staff.
6. The Laboratory does not give interpretation on test result passed/failed.



Chemist

(Bisahu Ram Sahu)

END OF THE REPORT

-----Page - 01 of 01-----



MANAGER
KRISHNA PUBLIC SCHOOL
KUTELABHATA, BHILAI-DURG (C.G.)



PRINCIPAL
KRISHNA PUBLIC SCHOOL
KUTELABHATA, BHILAI-DURG (C.G.)